

ADDENDUM # 2
CITY OF POWDER SPRINGS –RESURFACING PROJECT

April 12, 2021

For the Specifications Entitled:	Resurfacing Project
Publisher:	Chad Kastner, Croy Engineering
Bid Due Date:	April 19th 2021 11:00AM
Last Day for Questions:	April 7th 2021 5:00PM

This Addendum is issued to modify or interpret the bidding documents

Bidders are hereby instructed that the Specifications for the above referenced project are modified, corrected, or/and supplemented as hereinafter described. Bidders are hereby instructed to acknowledge receipt of this Addendum on the Bid Form.

Contents of Addendum:

- 1. Pre-Bid Minutes**
- 2. Pre-Bid Sign-In Sheet**
- 3. RFI #1**
- 4. Revised Bid Form**

**Resurfacing Project
Pre-Bid Meeting
March 31, 2021 at 10:00 a.m.**

1. Contacts
 - a. Program Management - Croy Engineering, LLC
 - i. Chad Kastner
 - b. Contractors – See attached Pre-bid sign-in sheet.
2. RFI
 - a. All questions should be sent in the form of an RFI to Chad Kastner at ckastner@croyeng.com
3. Addendum
 - a. Addendum #1 will be posted shortly which will include meeting minutes and all current RFI.
4. Plan Location
 - a. The bid set can be found at the city website
5. Work Hours
 - a. The work hours for the project will be restricted to Monday-Friday 7:00 A.M.- 6:00 P.M. and Saturday 9:00 A.M. - 6:00 P.M.
 - b. Lane Closures from 9:00 A.M. – 4:00 P.M.
6. Project Overview
 - a. Milling
 - b. Paving
 - c. Striping
7. Permits
 - a. Contractor is responsible for securing all permits and having all inspections completed in accordance with City Code.
8. Bid date
 - a. Bid Deadline is Tuesday April 13, 2021 at 10:00 A.M.
 - b. Last day for questions is Wednesday April 7, 2021 before 5:00 P.M.
 - c. All questions must be submitted to Chad Kastner with Croy Engineering ckastner@croyeng.com. Only questions in writing will be answered at which point will be redistributed to all contractors in the form of an addendum and distributed to pre-bid attendees.
9. Questions:
 - a. Will there be a self-perform requirement? Yes. The General Contractor is required to self-perform at least 35% of the work on the project with employees on staff in house.
 - b. Contingency: Contractor is not entitled to the contingency. This is to be used at the discretion of the city and with their approval.

Sign-In Sheet
Pre-Bid Conference for Resurfacing Project
Held on March 31, 2021 at 10:00 a.m.

Company Name

Representative

Phone No. and Email

Croy Engineering

Chad Kastner

770-971-5407 ckastner@croyengineering.com

City of Powder Springs

Dwayne Eberhart

770-943-8010 deberhart@cityofpowdersprings.org

CW Matthews

Chad Martin

770-422-7520 cmartin@cwmatthews.com

Blount Construction Company

Peter Psychogios

404-326-7677 peter.psychogios@blountconstruction.com

RFI #1

- 1). The proposal does not tell us what depth the 12.5MM surface is to be placed. Are we to place the 12.5MM surface at 1.50" depth? **Correct. 12.5mm should be installed at 1.5" depth**
- 2). How long will the contractor be allowed to let traffic run on the milled surface? **One week as long as the surface is safe.**
- 3). Using the descriptions of the roads listed in the proposal, we are coming up with right at 25,000 SY of Milled surface and based on 1.50" depth we are figuring right at 2,000 Tons of 12.5MM. This is substantially higher than the estimated quantities in the proposal. Can the City verify the descriptions of the included roads is correct? **Please use both areas in the bid form. This should have more than enough quantities.**
- 4). Will a MTV(Shuttle Buggy) be required for the asphalt items on this project? **No**

BID PROPOSAL FORM

CONTRACTOR _____

DATE _____

1. BASE BID:

Pursuant to and in compliance with the Advertisement for Bids and the Specifications relating to:

PROJECT NAME: City of Powder Springs Resurfacing of Various Streets

BID NUMBER: IFB 21-004

including Addenda (list addenda, if any) _____, the undersigned, having become thoroughly familiar with terms and conditions of the specifications and with local conditions affecting the performance, progress and cost of the work that is to be completed, hereby proposes and agrees to fully perform the work within the **Forty Five (45)** days timeframe stated and in accordance with the specifications including furnishing any or all services, labor, materials, and equipment authorized by the City and to do all the work required to complete said work in accordance with the specifications for the following unit prices:

Barnwood Pl, Bronco Ln, Daffodil Ln, Deer Creek Ct, Hadrian Ct, Buckhorn Ct					
Item ID	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	BID PRICE
150-1000	TRAFFIC CONTROL	1	LS		
402-1802	RECYCLED ASPH CONC PATCHING, INCL BITUM MATL & H LIME	409	TON		
402-1811	RECYCLED ASPH CONC LEVELING, INCL BITUM MATL & H LIME	100	TON		
402-4510	RECYCLED ASPH CONC 12.5 MM SUPERPAVE, GP 2 ONLY, INCL BITUM	610	TON		
413-1000	BITUM TACK COAT	350	GAL		
432-0206	MILL ASPH CONC PVMT, VARIABLE DEPTH	6520	SY		
432-0206	THERMOPLASTIC WHITE 12 INCH (STOP BARS)	120	LF		
	ADJUST MINOR STRUCTURES TO GRADE (ENCASED IN CONCRETE)	16	EA		
000-0000	CONTINGENCY	1	LS	30,000	

IFB # 21-004

Initial _____

Atlanta St, Brown Parkway, Elberta Terrace, Sharon Drive, Wylie Lane, Hopkins Ct, Christian Dr, Hopkins Crossing Dr, Josh Ct.

Item ID	DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	BID PRICE
150-1000	TRAFFIC CONTROL	1	LS		
402-1802	RECYCLED ASPH CONC PATCHING, INCL BITUM MATL & H LIME	1065	TON		
402-1811	RECYCLED ASPH CONC LEVELING, INCL BITUM MATL & H LIME	300	TON		
402-4510	RECYCLED ASPH CONC 12.5 MM SUPERPAVE, GP 2 ONLY, INCL BITUM	2850	TON		
413-1000	BITUM TACK COAT	1,650	GAL		
432-0206	MILL ASPH CONC PVMT, VARIABLE DEPTH	32,720	SY		
432-0206	THERMOPLASTIC WHITE 12 INCH (STOP BARS)	432	LF		
	THERMOPLASTIC WHITE CROSSWALK	650	SY		
	ADJUST MINOR STRUCTURES TO GRADE (ENCASED IN CONCRETE)	72	EA		
000-0000	CONTINGENCY	1	LS	30,000	

Total Base Bid Price

\$ _____

Bidder _____

Name _____

Signature _____

Titles _____

Date _____

Enclosed is a bid bond in the amount of 5% of the total bid price or (\$ _____)